

---

---

**Memphis-Shelby County Airport Authority (“Authority”)**

**Addendum No. 1  
To  
Request for Bids 12-1356-09  
For  
General DeWitt Spain Airport – Runway Rehabilitation - Construction**

**Issue Date: April 25, 2019**

**RECITALS**

**WHEREAS**, The Authority issued a certain Request for Bids MSCAA Project **12-1356-09 General DeWitt Spain Airport – Runway Rehabilitation - Construction** issued on 04/02/19 (the “RFB”); and

**WHEREAS**, The Authority now wishes to amend certain of the Specifications set forth in the RFB;

**NOW THEREFORE**, in consideration of the mutual covenants, agreements and conditions set forth in the RFB:

**ITEM NO. 1 GENERAL:** The terms “Sunset” and “Sunrise” shall be defined throughout the Contract Documents as “2000 to 0530.”

**ITEM NO. 2 PLAN SHEET 6 SAFETY AND PHASING PLAN PHASE 2:** Third Bullet under Phase 2A - 2E Heading: **DELETE** the phrase “BUT NOT TO EXCEED 750 LF” and **ADD** the following sentence: “IN NO CASE SHALL THE CONTRACTOR’S MILLING OPERATION EXCEED 750 L.F. IN FRONT OF THE CONTRACTOR’S PAVING OPERATION SO THAT IN THE EVENT OF AN EQUIPMENT MALFUNCTION OR UNEXPECTED SHUTDOWN, NO MORE THAN 750 L.F. OF MILLED SURFACE WILL BE EXPOSED.”

**ITEM NO. 3 PLAN SHEET 18 GRADING AND DRAINAGE:** **DELETE** the INLET PROTECTION DETAIL in its entirety and **REPLACE** with the attached Revised Inlet Protection Detail.

**DRAWING ATTACHMENTS:** The following drawing is included in this Addendum No. 1:

- Revised Inlet Protection Detail.

**INFORMATIONAL ATTACHMENTS:** The following informational attachment is included in this Addendum No. 1:

- Questions and Answers received through 5PM Monday, 04/22/19.

This addendum **must** be signed, to acknowledge receipt, and dated by the respondent and returned to the Authority as part of the respondents RFB response. Failure to do so may be grounds for disqualification of the response. The signed addendum, acknowledging receipt of Addendum No. 1 by the respondent, must be included in the response packet, immediately following the signed RFB.

---

In the event of conflict between the Specifications of the RFB and the Specifications of this Addendum, the Specifications of this Addendum shall prevail.

WITNESS the signature of the respective party by their duly authorized officer on the day and year herein written.

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Signature

Date: \_\_\_\_\_