

**QUESTIONS AND ANSWERS REGARDING
MSCAA PROJECT 12-1356-09
GENERAL DEWITT SPAIN AIRPORT – RUNWAY REHABILITATION - CONSTRUCTION
APRIL 25, 2019**

1.	Does the Contractor’s laboratory have to be AMRL Certified?
	Reference Section C100-7. The Contractor’s testing facilities shall meet the requirements of ASTM D3666. Documentation of ASTM D3666 certification may be through AMRL (AASHTO) or other similar agency certification.
2.	On the Unit Price Schedule – Base Bid, will Item No. 19 TS-129-5.2 Portable Lighted Runway Closure Markers LS 1 be provided by the airport?
	As shown on the Portable Lighted Runway Closure Marker (PLRCM) detail on Sheet 4, “Airport shall provide the Portable Lighted Runway Closure Marker(s), but the Contractor shall be responsible for the transport, fuel, bulbs and required maintenance during the use period.”

**The above questions were received through 5pm, Monday, 04/22/19.
Questions are listed as submitted, company names are withheld.**